

HSA-275/4+0

- Surge arresters type T2+T3 ensure the equipotential bonding and reduce switching, induced and residual overvoltage in LV power supply systems.
- The products consist of varistors with big discharge ability.
- Configurations 1+1 and 3+1 are additionally combined with a gas discharge tube which ensures zero leakage current through the PE conductor.
- Installed at the boundaries of LPZ 1 LPZ 3 into subsidiary switchboards and control panels.
- If the product contains two PE (or PEN) terminals, it must not be used as a PE (PEN) bridge.
- **M** indication specifies a type of construction with removable module.
- **S** indication specifies a version with remote monitoring.

| Test class according to EN 61643-11:2012 (IEC 61643-11:2011) System Number of poles Rated operating AC voltage Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $I_T = 5$ s Temporary overvoltage test (TOV) for $I_T = 120$ min Response time Maximal back-up fuse | $\begin{array}{c} U_N \\ U_C \\ I_{max} \\ I_n \\ U_{OC} \\ I_{Total} \end{array}$ | T2, T3 TN-S 4 230 V 275 V 50 kA 20 kA |
|---|--|---|
| Number of poles Rated operating AC voltage Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | U _C I_{max} I_{n} U_{OC} | 4 230 V 275 V 50 kA 20 kA |
| Rated operating AC voltage Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | U _C I_{max} I_{n} U_{OC} | 230 V 275 V 50 kA 20 kA |
| Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | U _C I_{max} I_{n} U_{OC} | 275 V 50 kA 20 kA |
| Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | I _{max} I _n U _{OC} | 50 kA 20 kA |
| Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | I _n U _{oc} | 20 kA |
| Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | U _{oc} | == |
| Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | | 0111 |
| Voltage protection level at I_n Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | I _{Total} | 6 kV |
| Voltage protection level at U_{OC} Temporary overvoltage test (TOV) for $t_T = 5$ s Temporary overvoltage test (TOV) for $t_T = 120$ min Response time | | 200 kA |
| Temporary overvoltage test (TOV) for $t_T = 5 \text{ s}$ Temporary overvoltage test (TOV) for $t_T = 120 \text{ min}$ Response time | U_p | < 1.2 kV |
| Temporary overvoltage test (TOV) for t_T = 120 min Response time | U _p | < 0.8 kV |
| Response time | U _T | 337 V |
| · | U _T | 440 V |
| Maximal back-up fuse | t _A | < 25 ns |
| | | 160 A gL/gG |
| Residual current | I _{PE} | ≤ 200 µA |
| Short-circuit current rating at maximum back-up fuse | I _{SCCR} | 60 kA _{rms} |
| Lightning protection zone | | LPZ 1-2, LPZ 2-3 |
| Housing material | | Polyamid PA6, UL94 V-0 |
| Degree of protection | | IP20 |
| Operating temperature | 9 | -40 ÷ 70 °C |
| Humidity range | RH | 5 ÷ 95 % |
| Minimum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022 (doesn't apply to "V" connection) for T2 | S | 2.5 mm ² (L, N) 6 mm ² (PE, PEN) |
| Clamp fastening range (solid conductor) | | 1.5 ÷ 25 mm ² |
| Clamp fastening range (stranded conductor) | | 1.5 ÷ 16 mm ² |
| Tightening moment | | 3 Nm |
| Installation | | On DIN rail 35 mm |
| Modular width | | 4 TE |




| Туре | | HSA-275/4+0 |
|--|---|---|
| Operating position | | Any |
| Product placement environment | | Internal |
| Signalling at the device | | Optic |
| Importance of local signaling | | OK – clear target FAULT – red target |
| Remote signalling | | No |
| Modular design | | No |
| Lifetime | | > 100 000 h |
| Designed according to standards | | |
| Requirements and test methods for SPDs connected to low-voltage power systems | | IEC 61643-11:2011 |
| Safety of Flammability of Plastic Materials | | UL 94 |
| Application standards | | |
| Protection against lightning | | IEC 62305:2010 |
| Selection and erection of electrical equipment – Switchgear and controlgear | | HD 60364-5-53:2022 |
| Selection and application principles for SPDs connected to low-voltage power systems | | CLC/TS 61643-12:2009 |
| Ordering, packaging and additional data | | |
| Mass | m | 380 g |
| Mass (including the packaging) | m | 408 g |
| Packaging dimensions (H x W x D) | | 74 x 112 x 73 mm |
| Packaging value | V | 0.61 dm ³ |
| ETIM group | | EG000021 |
| ETIM class | | EC000941 |
| Customs tariff no. | | 85363010 |
| EAN code | | 8590681115114 |
| Art. number | | 24 532 |



The link in the QR code leads to the online presentation of the **HSA-275/4+0**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com**



Application wiring diagram (installation)



Internal diagram

