

## HLA50-255/3+0

- Lightning impulse current arresters type T1 ensure the equipotential bonding and eliminate the effects of lightning current in single-phase and three-phase power supply systems.
- Products contain multiple non-exhausting spark gaps, thanks to which they are able to discharge the highest lightning impulse current.
- Suitable for objects with considerable levels of protection LPL I and LPL II, such as big industrial complexes and properties of particular importance hospitals, banks, power plants.
- Installed as close as possible the overhead line enters the building i.e. the electric power substation, electrometer or the main distribution boards.
- If the product contains two PE (or PEN) terminals, it must not be used as a PE (PEN) bridge.
- LED indication specifies a version with LED fault signalisation.
- **S** indication specifies a version with remote monitoring and LED fault signalisation.

| Туре  |                          | HLA50-255/3+0                    |
|---|--------------------------|----------------------------------|
| Test class according to EN 61643-11:2012 (IEC 61643-11:2011)  |                          | T1                               |
| System  |                          | TN-C                             |
| Number of poles   |                          | 3                                |
| Rated operating AC voltage  | U <sub>N</sub>           | 230 V                            |
| Maximum continuous operating voltage AC   | U <sub>c</sub>           | 255 V                            |
| Impulse discharge current for class I test (10/350)   | I <sub>imp</sub>         | 50 kA                            |
| Charge  | Q                        | 25 As                            |
| Specific energy for class I test  | W/R                      | 625 kJ/Ω                         |
| Total discharge current (10/350) L1+L2+L3->PEN  | I <sub>Total</sub>       | 150 kA                           |
| Nominal discharge current for class II test (8/20)  | l <sub>n</sub>           | 50 kA                            |
| Voltage protection level at I <sub>imp</sub>  | U <sub>p</sub>           | < 2 kV                           |
| Temporary overvoltage test (TOV) for $t_T = 5 s$  | UT                       | 337 V                            |
| Temporary overvoltage test (TOV) for $t_T = 120 \text{ min}$  | UT                       | 440 V                            |
| Response time   | t <sub>A</sub>           | < 100 ns                         |
| Maximal back-up fuse  |                          | 500 A gL/gG                      |
| Short-circuit current rating at maximum back-up fuse  | <b>I</b> <sub>SCCR</sub> | 25 kA <sub>rms</sub>             |
| Follow current interrupt rating   | l <sub>fi</sub>          | 25 kA <sub>rms</sub>             |
| Lightning protection zone   |                          | LPZ 0-1, LPZ 1-2                 |
| Housing material  |                          | Polyamid PA6, UL94 V-0           |
| Degree of protection  |                          | IP20                             |
| Operating temperature   | θ                        | -40 ÷ 70 °C                      |
| Humidity range  | RH                       | 5 ÷ 95 %                         |
| Minimum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022 (doesn't apply to ",V" connection) for T1 $$ | S                        | 6 mm² (L, N)<br>16 mm² (PE, PEN) |
| Clamp fastening range (solid conductor)   |                          | $2.5 \div 25 \text{ mm}^2$       |
| Clamp fastening range (stranded conductor)  |                          | $2.5 \div 16 \text{ mm}^2$       |
| Tightening moment   |                          | 4 Nm                             |
| Installation  |                          | On DIN rail 35 mm                |

## Lightning arresters T1




| Туре   |   | HLA50-255/3+0        |
|--|---|----------------------|
| Modular width  |   | 6 TE                 |
| Operating position   |   | Any                  |
| Product placement environment  |   | Internal             |
| Signalling at the device   |   | None                 |
| Remote signalling  |   | No                   |
| Modular design   |   | No                   |
| Lifetime   |   | > 100 000 h          |
| Designed according to standards  |   |                      |
| Requirements and test methods for SPDs connected to low-voltage power systems        |   | IEC 61643-11:2011    |
| Safety of Flammability of Plastic Materials  |   | UL 94                |
| Application standards  |   |                      |
| Protection against lightning   |   | IEC 62305:2010       |
| Selection and erection of electrical equipment – Switchgear and controlgear          |   | HD 60364-5-53:2022   |
| Selection and application principles for SPDs connected to low-voltage power systems |   | CLC/TS 61643-12:2009 |
| Ordering, packaging and additional data  |   |                      |
| Mass   | m | 690 g                |
| Mass (including the packaging)   | m | 734 g                |
| Packaging dimensions (H x W x D)   |   | 71 x 177 x 106 mm    |
| Packaging value  | V | 1.33 dm <sup>3</sup> |
| ETIM group   |   | EG000021             |
| ETIM class   |   | EC000381             |
| Customs tariff no.   |   | 85363010             |
| EAN code   |   | 8590681114803        |
| Art. number  |   | 10 972               |



**The link in the QR code** leads to the online presentation of the **HLA50-255/3+0**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com** 



## Application wiring diagram (installation)



## Internal diagram

