





HSA PV 1000/2 Module

- Removable modules for surge arresters type T2 intended for photovoltaic systems (PV).
- They are installed on the DC side in PV applications without an external LPS or with an external LPS, where the sufficient distance "s" is observed.
- Suitable for all LPL levels.

• Ensure the equipotential bonding of positive and negative busbars of PV systems and the elimination of transient overvoltage that originates during the atmospheric discharges or switching processes.

Туре		HSA PV 1000/2 Module
Test class according to EN 61643-11:2012 and EN 61643-31:2019		T2
Maximum continuous operating voltage (+/-)	U _{CPV}	1 000 V DC
Maximum continuous operating voltage (±/PE)	U _{CPV}	500 V DC
Nominal discharge current for class II test (8/20)	l _n	20 kA
Voltage protection level at In (+/-)	Up	< 3.8 kV
Voltage protection level at In (±/PE)	U _p	< 1.9 kV
Spare module for		27 238, 27 239
Designed according to standards		
Requirements and test methods for SPDs for photovoltaic installations		IEC 61643-31:2018
Safety of Flammability of Plastic Materials		UL 94
Application standards		
Protection against lightning		IEC 62305:2010
Selection and application principles for SPDs connected to photovoltaic installations		IEC 61643-32:2017
Selection and application principles for SPDs connected to photovoltaic installations		CLC/TS 51643-32:2020
Low-voltage electrical installations – Photovoltaic (PV) systems		HD 60364-7-712:2016
Ordering, packaging and additional data		
Mass	m	65 g
Mass (including the packaging)	m	76 g
Packaging dimensions (H x W x D)		26 x 98 x 73 mm
Packaging value	V	0.19 dm ³
Customs tariff no.		85363010
EAN code		8590681173145
Art. number		27 247



The link in the QR code leads to the online presentation of the **HSA PV 1000/2 Module**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com**





Internal diagram

